

WSPCert Certificate

No. BAC-0080-01

WSPCert attests the conformance of the following BACnet implementation to the BACnet standard ISO 16484-5:2012. The attested conformance refers to the BACnet Interoperability Building Blocks (BIBBs) listed in the annex of this certificate.

The BACnet Application Specific Controller (B-ASC)
**Humidity and Temperature Transmitter
HMW90**

with the software version:
1.0.0.0

of
Vaisala Oyj
Vanha Nurmijärventie 21, 01670 Vaanta, Finland

has fulfilled the requirements according to the test standard ISO 16484-6, the BTL Test Plan 9.0 and the Certification Rules of the BACnet Interest Group Europe, see **MBS Test Report No. VG 2012_7296**.

The certificate is valid
until 2014/04/01



WSPCert is accredited by
DAP GmbH according to EN 45011



2013/02/28

Date of initial certification



Dipl.-Ing. G. Weinmann
Head of Certification Body

Annex to Certificate No. BAC-0080-01

The certification of the BACnet Implementation
Humidity and Temperature Transm. HMW90
of **Vaisala Oyj**

refers to the BACnet Interoperability Building Blocks (BIBBs) listed below. BIBBs other than listed are not part of the certification.

BACnet Interoperability Building Blocks	
DS-RP-B	Data Sharing – Read Property – B
DS-RPM-B	Data Sharing – Read Property Multiple – B
DS-WP-B	Data Sharing – Write Property – B
DM-DDB-B	Device Management – Dynamic Device Binding – B
DM-DOB-B	Device Management – Dynamic Object Binding – B
DM-DCC-B	Device Management – Device Communication Control – B
DM-RD-B	Device Management – Reinitialize Device – B