VAISALA

CAB100 CMS Industrial Cabinet Analog Inputs

Large Cabinet for Analog Transmitter Inputs

Please choose one attribute from each numbered category and add the corresponding mark to the grid on top of the table.

As a result configuration code for the Vaisala device is formed. Example of order code with typical settings:

CAB100	B	1	H	0	N	0	0	N	B	1	N	1	N

Selections in bold are included in the prices of the basic versions.

Selections in italic are available at an extra price.

			1	2	3	4	5	6	7	8	9	10	11	12	13
Vaisala Industrial Cabinet Configuration			B	1		0	N	0	0	N			N		N
1. Cabinet size															
	Large	**600 x 500 x 200 (mm) / 23,6 x 19,7 x 7,9 (in)**	B												
2. Powering															
	Power supply	**110-240 VAC / 24 VDC**		1											
3. Analog Channels															
	None				N										
	4 pcs				A										
	8 pcs				B										
	12 pcs				C										
	16 pcs				D										
	20 pcs				E										
	24 pcs				F										
	28 pcs				G										
	32 pcs				H										
						0									
							N								
								0							
									0						
										N					
9. Communication															
	Port Server (DIGI TS4) qty 1	**1 port Ethernet RJ-45 10/100 Mbps**									A				
	Port Server (DIGI TS4) qty 2	*DIGI Port Server TS4*									B				
10. Ethernet Switch															
	None											0			
	1 pcs Ethernet Switch	*To optionally add number of Ethernet ports from 1 to 5 pcs, RJ-45 10/100 Mbps (not used in standard installation)*										1			
													N		
12. Housing Bottom Flange Material (Housing Top Flanges Rubber as standard)															
	Rubber flanges	**2 x 25 ports (Multigate MC25) with cable clamp bars**												1	
	Stainless Steel Flanges	*2 x 11 pcs EMC protected cable clands and 2 x 5 pcs optional ports*												2	
															N